


**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

**Clearview Regional School District**  
420 Cedar Road  
Mullica Hill, NJ 08062  
**Results of Lead Analysis**

Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
High School - Field Reagent Blank	08/25/2021 04:45	08/31/2021 11:41	<2.00	15.5	SM3113B
High School - HB - Outside Across From Grounds	08/25/2021 04:47	08/31/2021 11:48	7.70	15.5	SM3113B
High School - S-37 Stage Craft	08/25/2021 04:48	08/31/2021 11:54	17.86	15.5	SM3113B
High School - IM - 1 Boy's Aux Locker Room	08/25/2021 04:55	08/31/2021 12:01	<2.00	15.5	SM3113B
High School - WF - 1 Between Theatre Bathrooms	08/25/2021 04:49	08/31/2021 12:07	<2.00	15.5	SM3113B
High School - WF - 2 Between Theatre Bathrooms	08/25/2021 04:50	08/31/2021 12:27	<2.00	15.5	SM3113B
High School - S-38 A.D. Office	08/25/2021 04:57	08/31/2021 12:33	<2.00	15.5	SM3113B
High School -WF-5 New Girl's Locker Room Bathroom	08/25/2021 05:01	08/31/2021 12:40	<2.00	15.5	SM3113B
High School -HB-3 New Girl's Locker Room By IM	08/25/2021 05:02	08/31/2021 12:47	22.68	15.5	SM3113B
High School - WF - 4 Pioneer Hall By New Girl's LR	08/25/2021 05:06	08/31/2021 12:53	<2.00	15.5	SM3113B
High School - WF - 3 Pioneer Hall By New Girl's LR	08/25/2021 05:05	08/31/2021 13:00	<2.00	15.5	SM3113B
High School - WF - 9 BF Weight Room	08/25/2021 05:09	08/31/2021 13:06	2.55	15.5	SM3113B
High School - WF - 9 Weight Room	08/25/2021 05:10	08/31/2021 13:13	<2.00	15.5	SM3113B
High School - S-56 Trainer's Room	08/25/2021 05:11	08/31/2021 13:20	<2.00	15.5	SM3113B
High School - IM-4 Trainer's Room	08/25/2021 05:12	08/31/2021 13:26	<2.00	15.5	SM3113B
High School - HB-13 Trainer's Room	08/25/2021 05:13	08/31/2021 13:46	<2.00	15.5	SM3113B
High School - WF-6 Pioneer Hall By Trainer's Office	08/25/2021 05:14	08/31/2021 14:06	<2.00	15.5	SM3113B
High School - WF-7 Pioneer Hall By Trainer's Office	08/25/2021 05:15	08/31/2021 14:12	<2.00	15.5	SM3113B
High School - IM-3 New Boy's Locker Room	08/25/2021 05:16	08/31/2021 14:19	<2.00	15.5	SM3113B
High School - HB-14 New Boy's Locker Room	08/25/2021 05:17	08/31/2021 14:25	5.33	15.5	SM3113B
High School - WF-8 New Boy's Locker Room	08/25/2021 05:20	08/31/2021 15:20	<2.00	15.5	SM3113B
High School - WF-12 Hall By 703	08/25/2021 05:23	08/31/2021 15:27	7.95	15.5	SM3113B
High School - S-39 Room - 701	08/25/2021 05:24	08/31/2021 15:33	<2.00	15.5	SM3113B
High School - WF-14 Room - 701	08/25/2021 05:25	09/7/2021 17:23	<2.00	15.5	SM3113B
High School - WF-13 Room - 701	08/25/2021 05:26	09/7/2021 17:30	<2.00	15.5	SM3113B
High School - WF-15 Hall 700 & 100	08/25/2021 05:27	09/7/2021 17:49	<2.00	15.5	SM3113B
High School - S-4 Teacher's Planning Center	08/25/2021 05:29	09/7/2021 18:08	3.78	15.5	SM3113B
High School - WF-17 Teacher's Planning Center	08/25/2021 05:30	09/7/2021 18:15	<2.00	15.5	SM3113B
High School - WF-16 Hall -100 By Main Office	08/25/2021 05:31	09/7/2021 18:21	2.93	15.5	SM3113B
High School - S-2 Nurse's Station	08/25/2021 05:35	09/7/2021 18:27	<2.00	15.5	SM3113B
High School - S-1 Room 101	08/25/2021 05:38	09/7/2021 18:34	<2.00	15.5	SM3113B
High School - S-3 Nurse's Kitchen	08/25/2021 05:36	09/7/2021 18:40	9.40	15.5	SM3113B
High School - S-40 Room 109	08/25/2021 05:40	09/7/2021 18:46	25.99	15.5	SM3113B
High School - WF-18 Hall By Room 115	08/25/2021 05:42	09/7/2021 20:22	6.17	15.5	SM3113B
High School - S-24-A Room 712	08/25/2021 05:46	09/7/2021 19:05	6.28	15.5	SM3113B
High School - S-23 Room 714 Brown Kitchen	08/25/2021 05:47	09/7/2021 19:12	4.02	15.5	SM3113B
High School - S-22 Room 714 Black Kitchen	08/25/2021 05:48	09/7/2021 19:18	3.37	15.5	SM3113B

Units - ug/L = ppb



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006


## Clearview Regional School District

420 Cedar Road  
Mullica Hill, NJ 08062

### Results of Lead Analysis

Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
High School - S-21 Room 714 Red Kitchen	08/25/2021 05:49	09/7/2021 19:25	7.68	15.5	SM3113B
High School - S-20 Room 714 Blue Kitchen	08/25/2021 05:50	09/7/2021 19:31	2.85	15.5	SM3113B
High School - S-17 Room 714 Gray Kitchen	08/25/2021 05:51	09/7/2021 19:38	2.31	15.5	SM3113B
High School - S-18 Room 714 White Kitchen	08/25/2021 05:52	09/7/2021 19:44	<2.00	15.5	SM3113B
High School - S-19 Room 714 Prep Sink	08/25/2021 05:53	09/7/2021 19:50	<2.00	15.5	SM3113B
High School - WF-10 Old Boy's Locker Room	08/25/2021 05:55	09/7/2021 19:57	<2.00	15.5	SM3113B
High School - WF-24 Hall Across From 501	08/25/2021 05:56	09/7/2021 20:03	<2.00	15.5	SM3113B
High School - S-16 Teacher's Copy Room	08/25/2021 06:03	09/7/2021 20:42	<2.00	15.5	SM3113B
High School - S-14 Auxiliary Cafe	08/25/2021 06:05	09/7/2021 20:48	23.76	15.5	SM3113B
High School - S-15 Auxiliary Cafe	08/25/2021 06:06	09/7/2021 20:54	25.36	15.5	SM3113B
High School - S-25 Kitchen Old Cafe Side	08/25/2021 06:07	09/7/2021 21:01	<2.00	15.5	SM3113B
High School - S-27 Kitchen 3 Compartment Sink Left	08/25/2021 06:08	09/7/2021 21:07	<2.00	15.5	SM3113B
High School - PF-S-32 Kitchen Pot Filler By Stove	08/25/2021 06:09	09/9/2021 10:22	612.10	15.5	SM3113B
High School - S-24-B Kitchen New Cafe Side	08/25/2021 06:10	09/7/2021 21:59	15.45	15.5	SM3113B
High School - S-26 Kitchen 3 Compartment Sink Right	08/25/2021 06:12	09/7/2021 22:05	2.95	15.5	SM3113B
High School - S-34 Kitchen Prep Cooker	08/25/2021 06:13	09/7/2021 22:12	<2.00	15.5	SM3113B
High School - S-36 Kitchen	08/25/2021 06:14	09/7/2021 22:18	6.70	15.5	SM3113B
High School - S-29 Kitchen Coffee	08/25/2021 06:15	09/7/2021 22:24	2.11	15.5	SM3113B
High School - S-30 Kitchen Cold Prep	08/25/2021 06:16	09/7/2021 22:31	4.37	15.5	SM3113B
High School - S-33 Kitchen Prep Disposal	08/25/2021 06:17	09/7/2021 22:37	2.33	15.5	SM3113B
High School - IM- Kitchen	08/25/2021 06:18	09/7/2021 22:44	<2.00	15.5	SM3113B
High School - S-41 Room 502 1st	08/25/2021 06:25	09/7/2021 22:50	4.36	15.5	SM3113B
High School - S-412 Room 502 2nd	08/25/2021 06:26	09/7/2021 22:56	2.13	15.5	SM3113B
High School - S-50 Room 608	08/25/2021 06:27	09/7/2021 23:15	6.70	15.5	SM3113B
High School - S-51 Room 608	08/25/2021 06:28	09/9/2021 12:55	4.26	15.5	SM3113B
High School - S-52 Room 608	08/25/2021 06:29	09/9/2021 13:01	4.00	15.5	SM3113B
High School - S-7 Room 607 #1	08/25/2021 06:30	09/9/2021 13:08	<2.00	15.5	SM3113B
High School - S-8 Room 607 #2	08/25/2021 06:31	09/9/2021 13:14	2.70	15.5	SM3113B
High School - S-9 Room 607 #3	08/25/2021 06:32	09/9/2021 13:21	<2.00	15.5	SM3113B
High School - S-10 Room 607 #4	08/25/2021 06:33	09/9/2021 13:27	4.49	15.5	SM3113B
High School - S-11 Room 607 #5	08/25/2021 06:34	09/9/2021 13:33	<2.00	15.5	SM3113B
High School - S-12 Room 607 #6	08/25/2021 06:35	09/9/2021 13:53	<2.00	15.5	SM3113B
High School - S-13 Room 607 Prep Sink	08/25/2021 06:36	09/9/2021 13:59	<2.00	15.5	SM3113B
High School - S-53 Room 606	08/25/2021 06:37	09/9/2021 14:05	26.32	15.5	SM3113B
High School - S-54 Room 606	08/25/2021 06:38	09/9/2021 14:12	31.38	15.5	SM3113B
High School - S-47 Room 507	08/25/2021 06:40	09/9/2021 14:18	2.42	15.5	SM3113B
High School - S-44 Room 508	08/25/2021 06:43	09/9/2021 14:25	8.81	15.5	SM3113B

Units - ug/L = ppb



**South Jersey  
Water Test, LLC**

4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

**Clearview Regional School District**

420 Cedar Road  
Mullica Hill, NJ 08062

**Results of Lead Analysis**

Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
High School - S-43 Room 508	08/25/2021 06:44	09/9/2021 14:31	18.42	15.5	SM3113B
High School - S-45 Room 508	08/25/2021 06:45	09/9/2021 14:38	10.77	15.5	SM3113B
High School - S-46 Room 508	08/25/2021 06:46	09/9/2021 14:44	30.54	15.5	SM3113B
High School - WF-29 Hall By 229 Left	08/25/2021 07:15	09/9/2021 14:50	<2.00	15.5	SM3113B
High School - WF-30 Hall By 229 Right	08/25/2021 07:16	09/9/2021 15:10	<2.00	15.5	SM3113B
High School - S-48 Room 510-512 Prep	08/25/2021 06:50	09/9/2021 15:29	8.03	15.5	SM3113B
High School - S-59 Room 229-231 Prep	08/25/2021 07:17	09/9/2021 15:35	13.83	15.5	SM3113B
High School - S-49 Room 509-511 Prep	08/25/2021 06:51	09/9/2021 15:49	56.28	15.5	SM3113B
High School - WF-23 Hall Across Room 400	08/25/2021 06:53	09/9/2021 15:55	7.77	15.5	SM3113B
High School - WF-25 Hall Across Romm 217	08/25/2021 07:22	09/9/2021 16:01	<2.00	15.5	SM3113B
High School - WF-26 Hall Across Romm 217	08/25/2021 07:23	09/9/2021 16:08	<2.00	15.5	SM3113B
High School - S-55 Room 404	08/25/2021 06:55	09/9/2021 16:27	<2.00	15.5	SM3113B
High School - S-58 Room 212-214 Prep	08/25/2021 07:20	09/9/2021 16:34	26.26	15.5	SM3113B
High School - S-57 Room 219-221	08/25/2021 07:21	09/9/2021 16:53	174.80	15.5	SM3113B
High School - WF-21 Hall Across Room 411 Right	08/25/2021 07:00	09/9/2021 17:00	<2.00	15.5	SM3113B
High School - WF-22 Hall Across 411 Left	08/25/2021 07:01	09/9/2021 17:06	<2.00	15.5	SM3113B
High School - WF-27 Hall By 218 Right	08/25/2021 07:13	09/9/2021 17:13	<2.00	15.5	SM3113B
High School - WF-28 Hall By 218 Left	08/25/2021 07:12	09/9/2021 17:19	<2.00	15.5	SM3113B
High School - WF-19 Hall By 308 Right	08/25/2021 07:03	09/9/2021 17:25	<2.00	15.5	SM3113B
High School - WF-20 Hall By 308 Left	08/25/2021 07:02	09/9/2021 17:45	<2.00	15.5	SM3113B
High School - S-6 Room 302 TV Studio	08/25/2021 07:08	09/9/2021 17:51	3.58	15.5	SM3113B
High School - S-5 Media Center	08/25/2021 07:09	09/9/2021 17:58	<2.00	15.5	SM3113B

Mark J. Riether, Lab Director

9/13/21

Date